

222 Cavalcade Street, 77009-3213  
P.O. Box 8768, Houston, Texas 77249-8768  
Tel: (713) 692-9151 Fax: (713) 696-6205

*Attention: Grady Smith*

**SCAFFOLDMART**

234 Dudley Street

Greenville, NC 27858

P: (252) 756-3862 / F: 252/756-3849

W/O. No.: SCA021-04-10-54842-1

P.O. No.:

Report Date: 4/14/2009

**Identification:** Swivel Couplers


**Slip and Ultimate Load Testing**  
**Method: ANSI/SSFI SC100-5/05**  
**Coupler Nuts Tightened to 48 ft. lbs. Torque**

Coupler #	Slip Load (lbs)	Ultimate Load (lbs)
1	6,920	10,260
2	6,919	10,980
3	No slip	11,670

Our letters and reports are for the exclusive use of the client to whom they are addressed and shall not be reproduced except in full without the approval of the testing laboratory. The use of our name must receive our written approval. Our letters and reports apply only to the sample tested and/or inspected, and are not indicative of the quantities of apparently identical or similar products. Material submitted to our metals department will be discarded after a period of 30 days unless otherwise directed.

Stork SWL, is an operating unit of Stork Materials Technology B.V., Amsterdam, The Netherlands, which is a member of the Stork group

Respectfully Submitted

  
Terry Wilt  
Manager, Product Evaluation